

Flame Certificate  
Ruban by Kvadrat  
281940

**maharam**

Ruban by Kvadrat was tested and met the following flammability requirements:

Privacy Curtain: NFPA 701 - 1999 Test Method #1

Upholstered Walls: ASTM E 84 Unadhered flame 5, smoke 60

Windows: NFPA 701 - 1999 Test Method #1

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.