

Flame Certificate

Zoom by Kvadrat

282860

maharam

Zoom by Kvadrat was tested and met the following flammability requirements:

Privacy Curtain: NFPA 701 - 1999 Test Method #1

Upholstered Walls: ASTM E 84 Unadhered flame 5, smoke 60

Windows: NFPA 701 - 1999 Test Method #1

Contact clientservices@maharam.com with any questions.