

Flame Certificate
Squares by Kvadrat
283692

maharam

Squares by Kvadrat was tested and met the following flammability requirements:
Upholstered Walls: ASTM E 84 Unadhered flame 5, smoke 60
Windows: NFPA 701

Contact clientservices@maharam.com with any questions.