

Flame Certificate  
Casa by Kvadrat  
283751

**maharam**

Casa by Kvadrat was tested and met the following flammability requirements:

Privacy Curtain: NFPA 701

Upholstered Walls: ASTM E 84 Unadhered flame 15, smoke 20

Windows: NFPA 701

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.