

Flame Certificate
Pleat
395550

maharam

Pleat was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 10, smoke 30

Contact clientservices@maharam.com with any questions.