

Flame Certificate
Flaxen
397130

maharam

Flaxen was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 25, smoke 45

Contact clientservices@maharam.com with any questions.