

Flame Certificate

Shantung

398390

maharam

Shantung was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 25, smoke 45

Contact clientservices@maharam.com with any questions.