

Flame Certificate

Effect

398550

maharam

Effect was tested and met the following flammability requirements:

Upholstered Walls: ASTM E 84 Unadhered flame 25, smoke 55

Walls: ASTM E 84 Adhered flame 20, smoke 15

Contact clientservices@maharam.com with any questions.