

Flame Certificate

Dual

398630

maharam

Dual was tested and met the following flammability requirements:

Upholstered Walls: ASTM E 84 Unadhered flame 20, smoke 200

Walls: ASTM E 84 Adhered flame 15, smoke 65

Contact clientservices@maharam.com with any questions.