

Flame Certificate
Tek-Wall Parable
398650

maharam

Tek-Wall Parable was tested and met the following flammability requirements:

Upholstered Walls: ASTM E 84 Unadhered flame 20, smoke 200

Walls: ASTM E 84 Adhered flame 20, smoke 20

Contact clientservices@maharam.com with any questions.