

Flame Certificate
Tek-Wall Channel
399385

maharam

Tek-Wall Channel was tested and met the following flammability requirements:

Upholstered Walls: ASTM E 84 Unadhered flame 20, smoke 55

Walls: ASTM E 84 Adhered flame 15, smoke 5

Contact clientservices@maharam.com with any questions.