

Flame Certificate

Tek-Wall Stream

399389

maharam

Tek-Wall Stream was tested and met the following flammability requirements:

Upholstered Walls: ASTM E 84 Unadhered flame 25, smoke 55

Walls: ASTM E 84 Adhered flame 20, smoke 15

Contact clientservices@maharam.com with any questions.