

Flame Certificate  
Noble  
399394

**maharam**

Noble was tested and met the following flammability requirements:  
Walls: ASTM E 84 Adhered flame 25, smoke 40

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.