

# Flame Certificate

Basket

399412

**maharam**

Basket was tested and met the following flammability requirements:

Walls: ASTM E 84 Adhered flame 15, smoke 5

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.