

Flame Certificate
Tek-Wall View
399432

maharam

Tek-Wall View was tested and met the following flammability requirements:
Upholstered Walls: ASTM E 84 Unadhered flame 25, smoke 70
Walls: ASTM E 84 Adhered flame 20, smoke 15

Contact clientservices@maharam.com with any questions.