

Flame Certificate
Tek-Wall Measure Backed
399436

maharam

Tek-Wall Measure Backed was tested and met the following flammability requirements:

Upholstered Walls: ASTM E 84 Unadhered flame 25, smoke 70

Walls: ASTM E 84 Adhered flame 20, smoke 10

Contact clientservices@maharam.com with any questions.