

Flame Certificate
Living With That Person
399479

maharam

Living With That Person was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 10, smoke 0

Contact clientservices@maharam.com with any questions.