Flame Certificate Process 6 399482

maharam

Process 6 was tested and met the following flammability requirements: Walls: ASTM E 84 Adhered flame 10, smoke 0 $\,$

 $Contact\ clients ervices @maharam.com\ with\ any\ questions.$