

Flame Certificate
Along the Banks of Rivers High Above
399506

maharam

Along the Banks of Rivers High Above was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 10, smoke 0

Contact clientservices@maharam.com with any questions.