

Flame Certificate  
WHO'S AFRAID OF ST. LUKE?  
399508

**maharam**

Who's Afraid of St. Luke? was tested and met the following flammability requirements:  
Walls: ASTM E 84 Adhered flame 10, smoke 0

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.