

Flame Certificate  
Glass House May, 2008  
399512

**maharam**

Glass House May, 2008 was tested and met the following flammability requirements:  
Walls: ASTM E 84 Adhered flame 10, smoke 0

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.