

Flame Certificate  
Tek-Wall Drift  
399522

**maharam**

Tek-Wall Drift was tested and met the following flammability requirements:  
Walls: ASTM E 84 Adhered flame 15, smoke 20

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.