

Flame Certificate  
Recombinism  
by 2X4  
399532

**maharam**

Recombinism was tested and met the following flammability requirements:  
Walls: ASTM E 84 Adhered flame 10, smoke 0

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.