

Flame Certificate
Untitled (Demonstrations)
399541

maharam

Untitled (Demonstrations) was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 10, smoke 0

Contact clientservices@maharam.com with any questions.