

Flame Certificate

Chisel
399571

maharam

Chisel was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 20, smoke 45

Contact clientservices@maharam.com with any questions.