

Flame Certificate  
Birds of Paradise  
399574

**maharam**

Birds of Paradise was tested and met the following flammability requirements:  
Walls: ASTM E 84 Adhered flame 10, smoke 0

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.