

## Flame Certificate

Tek-Wall 1002

399594

**maharam**

Tek-Wall 1002 was tested and met the following flammability requirements:

Upholstered Walls: ASTM E 84 Unadhered

Walls: ASTM E 84 Adhered flame 10, smoke 20

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.