

Flame Certificate
Chalk
399616

maharam

Chalk was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 10, smoke 60

Contact clientservices@maharam.com with any questions.