

Flame Certificate

Tile

399621

maharam

Tile was tested and met the following flammability requirements:

Walls: ASTM E 84 Adhered flame 5, smoke 5

Contact clientservices@maharam.com with any questions.