

Flame Certificate

Cue

399634

maharam

Cue was tested and met the following flammability requirements:

Walls: ASTM E 84 Adhered flame 25, smoke 45

Contact clientservices@maharam.com with any questions.