

Flame Certificate
Mixed Stripe
by Paul Smith
399652

maharam

Mixed Stripe was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 15, smoke 35

Contact clientservices@maharam.com with any questions.