

Flame Certificate  
Gradient Dot  
by Paul Smith  
399655

**maharam**

Gradient Dot was tested and met the following flammability requirements:  
Walls: ASTM E 84 Adhered flame 25, smoke 45

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.