

Flame Certificate

Debut

399678

maharam

Debut was tested and met the following flammability requirements:

Walls: ASTM E 84 Adhered flame 15, smoke 35

Contact clientservices@maharam.com with any questions.