

Flame Certificate

Comb

399689

maharam

Comb was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 20, smoke 45

Contact clientservices@maharam.com with any questions.