

Flame Certificate
Watercolor Flowers
by Sanaa
399745

maharam

Watercolor Flowers was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 20, smoke 5

Contact clientservices@maharam.com with any questions.