

Flame Certificate
Circle Cutter's Room
by Rosemarie Trockel
399755

maharam

Circle Cutter's Room was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 20, smoke 5

Contact clientservices@maharam.com with any questions.