

Flame Certificate
Multi Stripe
by Paul Smith
399800

maharam

Multi Stripe was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 25, smoke 45

Contact clientservices@maharam.com with any questions.