

Flame Certificate

Dice

by Paul Smith

399816

maharam

Dice was tested and met the following flammability requirements:

Walls: ASTM E 84 Adhered flame 20, smoke 5

Contact clientservices@maharam.com with any questions.