

## Flame Certificate

Spin

399833

**maharam**

Spin was tested and met the following flammability requirements:

Walls: ASTM E 84 Adhered flame 10, smoke 45

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.