

Flame Certificate
Lantern
399897

maharam

Lantern was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 5, smoke 10

Contact clientservices@maharam.com with any questions.