

Flame Certificate

Husk

399933

maharam

Husk was tested and met the following flammability requirements:

Walls: ASTM E 84 Adhered flame 20, smoke 45

Contact clientservices@maharam.com with any questions.