

Flame Certificate
Chockstones, Craggs and Edging Paint
399943

maharam

Chockstones, Craggs and Edging Paint was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 10, smoke 0

Contact clientservices@maharam.com with any questions.