

Flame Certificate  
Tek-Wall Tusk  
399945

**maharam**

Tek-Wall Tusk was tested and met the following flammability requirements:  
Upholstered Walls: ASTM E 84 Unadhered flame 15, smoke 75  
Walls: ASTM E 84 Adhered flame 25, smoke 30

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.