

Flame Certificate
Antidote
by Raqs Media Collective
399948

maharam

Antidote was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 20, smoke 5

Contact clientservices@maharam.com with any questions.