Flame Certificate Spate 399950

maharam

Spate was tested and met the following flammability requirements: Walls: ASTM E 84 Adhered flame 20, smoke 45 $\,$

 $Contact \ clients ervices @ maharam.com \ with \ any \ questions.$