

Flame Certificate
Bundle
399957

maharam

Bundle was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 10, smoke 45

Contact clientservices@maharam.com with any questions.