

Flame Certificate

Tether

399961

maharam

Tether was tested and met the following flammability requirements:

Walls: ASTM E 84 Adhered flame 25, smoke 45

Contact clientservices@maharam.com with any questions.