

## Flame Certificate

Esker

399967

**maharam**

Esker was tested and met the following flammability requirements:

Walls: ASTM E 84 Adhered flame 20, smoke 35

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.