

Flame Certificate

Metric

466014

maharam

Metric was tested and met the following flammability requirements:

Seating: California Bulletin #117-2013

Upholstered Walls: ASTM E 84 Unadhered flame 15, smoke 85

Contact clientservices@maharam.com with any questions.