

Flame Certificate

Bar

466227

maharam

Bar was tested and met the following flammability requirements:

Seating: California Bulletin # 117-2013, NFPA 260

Upholstered Walls: ASTM E 84 Unadhered flame 15, smoke 90

Contact clientservices@maharam.com with any questions.